LISTING SERVICE

LISTING No.   7135-1483:101   Page 1 of 1

CATEGORY: Audible Devices

LISTEE: Mirtone, 90 Fieldstone Ct., Cheshire, CT 06410
Contact: Brad Miller (888) 649-9827 Fax (203) 699-3108

DESIGN: Explosion-proof Models 74331U and 74333U vibrating bells. Refer to listee's data sheet
for additional detailed model description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances
and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, hazardous location classification and UL label.

APPROVAL: Listed as audible devices for use with separately listed compatible control units. Explosion-
proof models intended for use in Class I, Groups B, C, D; Class II, Groups E, F, G hazardous
locations.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire
Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999
Edition, the appliance must be used with a fire alarm control unit that can generate the
temporal pattern signal. Refer to manufacturer's Installation Manual for details.

XLF: 7135-1388:110

3-26-97

Date Issued: **JUNE 20, 2003**   *Listing Expires* **June 30, 2004**

A*uthorized By:*   **DIANE K. AREND**, *Senior Deputy*
Program Manager